



Somervell County Water District

Primary Business Address
2099 CR301
P.O. Box 1386
Glen Rose, TX 76043
Phone: 254-897-4141
Fax: 254-897-7461
E-mail: SCWD@SCWD.com

Disinfection Data

The District uses sodium hypochlorite as its disinfectant, our supplier is Hydro-Plus Inc. The disinfectant residual is measured in free chlorine in mg/L. The MRDL and MRDLG for chlorine is 4.0 mg/L as set by the EPA. Below are The Districts highest and lowest single results for the year 2012.

Disinfectant	Highest single result	Lowest single result
Chlorine;Free	3.80 mg/L	1.38 mg/L



Definitions

- MCL** : Maximum contaminant level, the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- MCLG** : Maximum contaminant level goal, the level of contaminant in drinking water below which there is no known or expected health risk. MCLGs allow for a margin of safety.
- pCi/L** : Picocuries per liter (a measure of radioactivity)
- ppb** : micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
- ppm-mg/l** : milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
- MRDL** : The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- MRDLG** : Maximum residual disinfectant level goal, the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

SOMERVELL COUNTY WATER DISTRICT

Get Involved

Board meetings take place the second Monday of every month at The Districts Administrative office located at 2099 CR301, Glen Rose, Texas. Meetings start at 7:00PM. For addition info or to see when the next meeting will take place refer to the districts website at www.scwd.com

Whats This?

This is your yearly consumer confidence report, this report contains chemical analysis of your drinking water for the year 2012. For additional information on the contents of this report please contact:

Kevin Taylor
General Manager

Phone 254-897-4141
Fax 254-897-7461
Email scwd@scwd.com

Water Report

2012 CONSUMER CONFIDENCE REPORT

Your Water

Your water comes from Wheeler Branch Reservoir. Wheeler Branch Reservoir is a man made lake located approximately one mile north of Glen Rose. The lake is around 180 acres in surface area and can yield 2000 acre feet of water per year, or about 650 million gallons.. A Source Water Assessment for your drinking water source is currently being con-



Wheeler Branch Reservoir

the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information in this assessment will allow us to focus our source water protection strategies.

ducted by the TCEQ and should be provided to us this year. The report will describe

Water and your Health

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791). Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as

persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the districts administrative office.

"Este reporte incluye informacion importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (254) 897-4141.



Lead in the Water?

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The District is responsible for providing high quality drinking water, but cannot control the variety of materials used in

plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water,

testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Contaminants in the Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

*EPA considers 50 pCi/L to be the level of concern for beta particles

Contaminant	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Lead and Copper	2012	0	15	6.31	0	ppb	n	corrosion of household plumbing systems; erosion of natural deposits
Copper	2012	1.3	1.3	1	0	ppm	N	erosion of natural deposits; leaching from wood preservatives; corrosion of household plumbing systems
Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloaetic Acids (HAA5)	2012	68	67.8-67.8	No goal for the total	60	ppb	N	by-product of drinking water disinfection
Total Trihalomethanes (THM)	2012	235	234.6-234.6	No goal for the total	80	ppb	N	by-product of drinking water disinfection
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic	2012	2.19	2.19-2.19	0	10	ppb	N	erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium	2012	0.0518	0.0518-0.0518	2	2	ppm	N	discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium	2012	0.843	0.843-0.843	100	100	ppb	N	discharge from steel and pulp mills; erosion of natural deposits
Fluoride	2012	0.3	0.3-0.3	4	4.0	ppm	N	erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate [measured as nitrogen]	2012	1	0.1-45	10	10	ppm	N	runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium	2012	4.88	4.88-4.88	50	50	ppb	N	discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/photon emitters	2012	5	5-5	0	50	pCi/L*	N	decay of natural and man-made deposits

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.