



## SOMERVELL COUNTY WATER DISTRICT

2099 CR 301 • P. O. Box 1386 • Glen Rose, Texas 76043

Office (254) 897-4141 • Fax (254) 897-7461

### **PROCEDURE FOR WATER SERVICE**

If you are currently connected to a private water well, the line will have to be physically disconnected from the well before SCWD can connect a meter.

SCWD will have to perform a Customer Service Inspection of the plumbing in your house to assure compliance with Texas Commission on Environmental Quality requirements.

SCWD will coordinate with the customer when the well connection can be removed and the meter set and connected. This will be required to be done during normal business hours.

SCWD will inform the customer the approximate working pressure that will be supplied at the tap.

Some customers may require a pressure reducing valve at their delivery point. In some areas pressures may exceed 70psi.